



THE IMPACT OF SMALL SCALE EMBEDDED GENERATION AND EEDSM ON HISTORICALLY DESIGNED NETWORKS AND HOW IT WILL AFFECT NETWORKS OF FUTURE CITIES

Presented by:

Jaco Alberts Pr Eng

7 October 2014





CONTENTS

- Background
- Typical planning and design parameters
- EEDSM impact
- SSEG impact
- Conclusion
- Questions

BACKGROUND

- Energy Efficiency, DSM, Renewables implemented on existing networks – are original design parameters revisited?
Compliance?
- Small scale embedded generators (SSEG): embedded in distribution network. National Network System Operator does not have control over them. Do Utilities know about each and every SSEG generator?
- SSEG typically uncontrolled from utility point of view.
 - Consumers do what they want.
 - Create safety problems (reverse power flow).
 - Do all grid connected SSEG's comply with requirements (RPP Grid Code; NRS 097-2-1; NRS097-2-2; NRS097-2-3)?

DESIGN AND PLANNING PARAMETERS DETERMINISTIC METHODS

<p>Coincidence; Diversity</p> <p>MD= Max. demand</p>	<p><i>Coincidence</i> =</p> <p><i>Diversity</i> = $\frac{1}{C_c}$</p> 
<p>ADMD (after diversity MD)</p> <p>N=No of Consumers DF = Diversity correction factor k = Coincidence</p>	<p>$MD = N \times DF$</p> <p>$ADMD = \lim_{N \rightarrow \infty} \frac{MD}{N}$</p> <p>$DF = 1 + \frac{k}{N}$</p> 

DESIGN AND PLANNING PARAMETERS STATISTICAL METHODS

**Herman
Beta
method
(NRS034):**

**ADMD (A) =
 μ**

**C = Circuit
breaker size
(A)**

$$p(x) = \frac{x^{\alpha-1}(1-x)^{\beta-1}}{B(\alpha, \beta)} \quad 0 < x < 1$$



Where $B(\alpha, \beta) = \int_0^1 u^{\alpha-1}(1-u)^{\beta-1} du$

$$\alpha = \frac{\mu(c\mu - \mu^2 - \sigma^2)}{c\sigma^2}$$


$$\beta = \frac{(c - \mu)(c\mu - \mu^2 - \sigma^2)}{c\sigma^2}$$

$$\mu = c \frac{\alpha}{\alpha + \beta}$$


$$\sigma^2 = c^2 \frac{\alpha\beta}{(\alpha + \beta)^2(\alpha + \beta + 1)}$$



EEDSM




ENERGY EFFICIENCY




DEMAND SIDE
MANAGEMENT

EXAMPLE: ADMD IMPACT OF RIPPLE CONTROL (DSM INITIATIVE)



RIPPLE CONTROL EXAMPLE LOAD FLOW



ADMD (kVA)	Trf load (kVA)	Min V_{nom} (%)	Cable load (% of rated current)	% LV reach @ 90% V_{nom}
Tapered LV cable feeder (A)				
5.3 design	478	90.14	77	100
5.8 (11.6%)	519	89.28	84	73
6.25 (25%)	560	88.44	91	60
One size LV cable feeder (B)				
5.3 design	478	91.34	88	100
5.8 (11.6%)	519	90.59	96	100
6.25 (25%)	560	89.85	104	85

**5 kVA present avg. demand per consumer.
Designed 5.3 kVA ADMD
5 kVA + 11.6% = 5.8 kVA; 5 kVA + 25% = 6.25 kVA**

RIPPLE CONTROL LOAD FLOW OBSERVATIONS





- Increase in ADMD will change Herman-Beta volt drop method parameters.
- Increased ADMD resulted in volt drop exceeding limits (90% p.u. at consumer distribution board)
- Tapered LV feeders are at greater risk
- Transformer overload within overload specifications of transformers
- Single size LV feeder overload occurred for section close to transformer.

SMALL SCALE EMBEDDED GENERATION

GENERATION

SOLAR PV




Typical residential profile:

- Averaged consumer profile 5.3kVA ADMD
- Individual profile shape of course different
- 3kW PV at unity power factor
- Potential surplus energy at low demand conditions

SSEG STUDY EXCLUSIONS

- Considered only PV. Micro wind and other forms of SSEG excluded
- Considering only class A1 (<13.8kVA, i.e. 60A single phase), as defined in the RSA RPP Grid Code.
- Solar PV related issues excluded from this paper:
 - safety related issues
 - metering, tariff, billing and revenue related issues
 - protection & fault level studies
 - power factor impact
 - technical losses
 - Grid tie inverter specifications and capabilities




NRS 097: MAX EMBEDDED GENERATION ALLOWED

TOTAL LV GENERATION:

- 75% max of TRFR rating

DEDICATED LV FEEDER CONSUMER GENERATORS:

- Max 75% of consumer NMD
- Max 1ph: 13.8kVA
- >4.6kVA: Balanced 3ph




MV FEEDER GENERATORS:

- 15% max of feeder peak load

SHARED LV FEEDER CONSUMER GENERATORS:


- Max 25% of consumer NMD
- Total shared: max 25% of TRFR rating
- >4.6kVA: Balanced 3ph
- Max individual limit: 20kVA

SSEG EXAMPLE LOAD FLOW STUDY RESULTS – 3kW PV



Scenario	Trf load (kVA)	Min V %	Max V %
3kW solar PV embedded generator systems			
<u>Tapered LV feeder (A):</u>			
No generator connected	150	101.40	103.42
25% penetration close to transformer	90	101.60	103.56
25% penetration at end of feeder	90	102.02	103.76
100% penetration	-68	103.67	105.33
<u>One size LV feeder (B):</u>			
No generator connected	150	101.64	103.42
25% penetration close to transformer	90	101.85	103.56
25% penetration at end of feeder	90	102.12	103.58
100% penetration	-77	103.68	105.23

SSEG EXAMPLE LOAD FLOW STUDY RESULTS – 9kW PV





Scenario	Trf load (kVA)	Min V %	Max V %
9kW solar PV embedded generator systems			
<u>Tapered LV feeder:</u>			
No generator connected	150	101.40	103.42
25% penetration close to transformer	42	101.82	103.90
25% penetration at end of feeder	42	102.95	107.34
100% penetration	-247	104.15	111.96
<u>One size LV feeder:</u>			
No generator connected	150	101.64	103.42
25% penetration close to transformer	42	102.09	103.95
25% penetration at end of feeder	42	102.93	106.48
100% penetration	-255	104.17	111.26

ILLUSTRATING VOLTAGE RISE FOR LV SSEG SYSTEMS

100% SSEG penetration
3kW systems

25% SSEG penetration 3kW
systems – at end of feeder



SSEG LOAD FLOW OBSERVATIONS

- Voltage rise:


- Will be worse when voltage boost exists, e.g. 415V and 420V transformer secondary voltage at nominal tap.
- Voltage regulation relative to Declared Nominal Voltage (400V three phase, 230V single phase)
- MV/LV Transformers usually have fixed taps.



- Reverse flow of energy across transformer into MV network
- Although no cables were overloaded in these examples, increasing the amount each house can inject under low load conditions, e.g. to 60A, will result in conductor overload. Important to maintain designed network diversity

OTHER OBSERVATIONS FOR FURTHER STUDY

- Fault level increases as generators are added. Traditionally, the fault level decreased downstream for the same voltage level. **Are cables and equipment still adequately rated for faults?**
- Power factor worsens (injecting only kW, not kVAr).



$\cos(\phi) = \text{power factor}$

Generated PV

CONCLUSION

- DSM measures implemented, e.g. ripple control, changed design parameters, however network designs have never been revisited.
- SSEG can reduce the network's demand on grid power
- However, there is a risk of voltage rise beyond regulation limits, especially close to the transformer if not "controlled"
- Potential loss of design diversity during low load conditions under reverse power flow conditions

END
THANK YOU
QUESTIONS?