

# **TECHNICAL AND FINANCIAL IMPACTS OF RESIDENTIAL PV- BATTERY SYSTEMS**

**Author and Presented by  
Miriam S Thopil**

**Co-Authors  
GV Moodley and Dr GD Jennings**

**DIG SILENT BUYISA (PTY) LTD**



# Overview

---

- Objective of study.
- Simulation Model and Assumptions.
- Impacts on Power Flow.
- Impacts on Energy.
- Impacts on Revenue- Fixed rate vs Time of Use Tariff.
- Conclusions.



# Objective of Study

---

The objective is to determine impact of **PV only**, **battery only** and **combination** thereof on MV networks for:

- **Technical**: impact on **power flow profile**.
- **Financial**: impact on **revenue** when considering **time of use** and **fixed rate tariffs**.

## Important questions:

- How will **battery storage and PV installations** affect power flow profiles in MV networks?
- With increasing availability of battery storage, can the **utility expect a reduction in revenue**?
- What is the **ideal tariff structure** to implement that will **minimise revenue loss** with increased PV and storage in networks?



## Simulation Model


---

- Network used was Flora Park in Polokwane Municipality with 87% residential and 13% commercial clients.
- The network has a total installed MV/LV transformer capacity of 13.2 MVA.
- All consumers have 60 A breakers (13.8 kVA).
- All studies were done using [Digsilent PowerFactory 2018](#).




# Load Profiles

- Assumed that network loading can reach 100% of the total MV/LV transformer capacity.
- Peak network loading occurs in winter with the summer peak approximately 40% of the winter peak.



Residential Consumer




Commercial Consumer



## PV Profiles

- Since all customers are on a **shared feeder**, as per **NRS 097-2-3** PV installations are **limited to 25%** of the total NMD, i.e. max PV= 3.45 kVA/consumer (25% of 13.8 kVA).
- Peak PV output is achieved in summer with **winter peak output approximately 80% of summer output.**





# Battery System




---

- Li-ion type, 52 V-460 Ah-24 kWh.
- The maximum charge is set to **3.64 kW**. The maximum discharge is set to **7.28 kW**.
- Controller determines battery charge/discharge logic, and therefore **3 different battery profiles** are considered:
  - Full discharge.
  - Load following.
  - Conservative discharge.



# Battery Charge/Discharge Profiles

- **Full discharge:** Batteries discharge their **full rated output** during peak periods regardless of load demand.
- **Load following discharge:** Batteries discharge so that it **matches the load** value subjected to its maximum rated output limit.
- **Conservative discharge:** Batteries discharge to **50% of its maximum rated output**, regardless of the load demand.









## Study Assumptions

---

- All consumers are assumed to have PV and battery systems installed. No statistical dispatch of PV / battery systems were considered, hence:
  - 0% PV/Battery means all of the PV / battery systems are off.
  - 40% PV/Battery means the all the PV and battery systems outputs are limited to 40% of rating.
  - 100% PV/battery means the all the PV and battery systems outputs are on fully i.e. 100% of rating.
- Studies were done considering all battery profiles. Results showed very similar trends. For simplicity ONLY load following battery charge/discharge profile results are presented.





# Impacts on Power Flow – PV Only



- Typical in networks with PV, **duck curve** is observed in summer and winter.
- During summer season, **reverse power flow to HV network** occurs.
- Adding **PV only** to the network **fails to overcome the traditional double peak**.





# Impacts on Power Flow – Battery Only (load following profile)



- With **40% battery** a **smoothing effect** is observed for the profiles.
- There is **increased loading** observed during **traditional off peak** due to charging.
- During **peak times** in the morning and evening, **peak shaving** can be observed.





# Impacts on Power Flow – Battery Only (load following profile)



- When **100% Battery**, there is a **significant change** in the power flow profile.
- There is a **increased loading** noted during **traditional off-peak** times.
- During **traditional peak times** in the morning and evening, **dips** in power flow are now observed.




# Impacts on Power Flow – PV and Battery



- With **100% PV and batteries**, there is now an increased **night loading**.
- **Midday loading** observed with battery only is **removed** due to battery charging from PV.
- In **summer**, there is **backfeed to the HV network**.
- **Peak shaving** (40% case) and **dips** (100% case) occur at traditional morning and evening peak times respectively.




# Impacts on Daily Energy Sold



- Reduction in energy sold is noted for PV scenarios.
- Batteries only cause NO reduction in energy sold. They only shift when the energy is sold.




## Impacts on Revenue – Fixed Rate Tariff



- Reduction in revenue is noted for PV scenarios.
- Batteries only cause NO reduction in revenue for fixed rate tariff.



## Impacts on Revenue – Time of Use Tariff



- **Reduction in revenue** is noted for **battery only scenarios**.
- **Largest revenue loss** is noted when **PV and batteries** are installed and a **time of use tariff** structure is in place.






# Conclusions

- How will battery storage and PV installations affect power flow profiles in MV networks?
  - PV Only: Mid-day dips and reverse power flow in low loading cases.
  - Battery Only: Load shifting resulting in increased midday/midnight loading and dips with high penetration. Peak shaving achieved with balanced penetration.
  - PV and Battery: PV helps to reduce mid-day loading, traditional peaks now become dips for very high penetration levels.
- With increasing availability of battery storage, can the utility expect a reduction in revenue?
  - Depends on the tariff: No reduction expected for fixed rate tariff.
  - Reduction expected if on time of use tariff.
- What is the ideal tariff structure to implement that will minimise revenue loss with increased SSEG and storage in networks?

Networks with more PV

Networks with more batteries





---

**Miriam Thopil**

**Digsilent Buyisa (Pty) Ltd**

**Tel: 087 351 6159**

**[info@digsilent.co.za](mailto:info@digsilent.co.za)**

**THANK YOU**